

---

## CERTIFICATE OF QUALITY TEST

---

Date:

**Aston Inc.**

14-16 Yasakahonmachi, Kita-ku  
Okayama-shi, Okayama Japan  
TEL: +81-86-255-1511



Product Name     **CS-21 Neo (Concrete Renovation)**

---

Serial Number       00000000

---

Test Items	Product Specifications	Test Value	Unit	Test Conditions
Appearance	Colorless and transparent No foreign bodies	No abnormality	--	Visual test by Company Standard
pH Value	11.0 - 13.0	00.0	--	JIS K0102-12.1
Specific Gravity (Density)	1.100 - 1.140	0.000	(g / cm <sup>3</sup> )	JIS K2249
Dry Solid Content	15.0 - 20.0	00.0	%	JSCE K572-6.2

This is to certify the quality of product specifications as above.

---

# CERTIFICATE OF QUALITY TEST


---

SAMPLE

Date:

Aston Inc.

14-16 Yasakahonmachi, Kita-ku  
Okayama-shi, Okayama Japan  
TEL: +81-86-255-1511



Product Name **CS-21 Neo (Concrete Renovation)**

---

Serial Number

---

Test Items	Product Specifications	Test Value	Unit	Test Conditions
Appearance	Colorless and transparent No foreign bodies	No abnormality	--	Visual test by Company Standard
pH Value	11.0 - 13.0	11.8	--	JIS K0102-12.1
Specific Gravity (Density)	1.100 - 1.140	1.120	(g / cm <sup>3</sup> )	JIS K2249
Dry Solid Content	15.0 - 20.0	15.9	%	JSCE K572-6.2

This is to certify the quality of product specifications as above.